



Legislation Details (With Text)

File #: R-2016-112 **Version:** 1 **Name:** AWC, Inc - Purchase of two Process Flow Meters
Type: Resolution **Status:** Passed
File created: 3/30/2016 **In control:** Department of Public Utilities
On agenda: 4/20/2016 **Final action:** 4/20/2016
Title: A Resolution Of The City Commission Of The City Of Hollywood, Florida, Authorizing The Use Of The City's Sole Source Exemption To Issue A Purchase Order To AWC Incorporated For The Purchase Of Two Process Flow Meters For Oxygenation Trains 1 And 2 Located At The Southern Regional Wastewater Treatment Plant In An Amount Of \$64,400.00.

Sponsors:

Indexes:

Code sections:

Attachments: 1. Reso - AWC Process Flow Meters Sole Source.pdf, 2. AWC Sole Source.pdf, 3. TermSheetAWCPurchaseOrderSoleSource.pdf, 4. BIS 16-149.pdf

Date	Ver.	Action By	Action	Result
4/20/2016	1	Regular City Commission Meeting	adopt	Pass

A Resolution Of The City Commission Of The City Of Hollywood, Florida, Authorizing The Use Of The City's Sole Source Exemption To Issue A Purchase Order To AWC Incorporated For The Purchase Of Two Process Flow Meters For Oxygenation Trains 1 And 2 Located At The Southern Regional Wastewater Treatment Plant In An Amount Of \$64,400.00.

Staff Recommends: Approval of the Attached Resolution.

Explanation:

The Department of Public Utilities run and operate the Southern Regional Wastewater Treatment Plant ("SRWWTP").

The SRWWTP utilizes several flow meters to monitor the amount of raw and treated wastewater, chemicals and additives that continuously circulate all through the diverse array of the treatment processes.

The influent flows for Oxygenation Trains 1 and 2 are measured via two (2) ABB 54-inch WaterMaster Electromagnetic flow meters.

The existing flow meters have reached their useful lives and their internal coil insulations are failing, causing the meters to give erratic flow readings and/or at times no flow readings at all.

The ABB WaterMaster Electromagnetic flow meters are sold exclusively through the authorized representative, AWC Incorporated of Altamonte Springs, Florida.

On March 17, 2016, the Procurement Services Division posted Notice to Sole Source Number NTSS-027-16 to purchase two (2) ABB 54" WaterMaster Electromagnetic Flow Meter Systems, issued an electronic notification to various vendors, and identified March 23, 2016, as the posting expiration date.

The Procurement Services Division received no inquiries or comments on the Notice to Sole Source Number NTSS-027-16, and Section 38.40(C)(3) of the City's Purchasing Ordinance exempts sole source supplies and services, such as unique, patented or franchised supplies or services, from the competitive bid requirements.

Funding for Emergency Projects has been provided via Resolution No. R-2015-345 which continued the appropriation for previously approved Capital Projects from FY2015 to FY2016, and is available in the account number 42.4000.86532.536.006302.

The Director of Public Utilities and the Procurement Services Division recommend that the City Commission issue a purchase order to AWC Incorporated for the purchase of two (2) ABB 54" WaterMaster Electromagnetic Flow Meter Systems in an amount of \$64,400.00.

Recommended for inclusion on the agenda by:

Wazir A. Ishmael, City Manager

Mirtha Dziedzic, Interim Director, Financial Services

Steve Joseph, Director, Public Utilities

Paul Bassar, Contract Compliance Officer, Office of the City Manager