

City of Hollywood

Legislation Details (With Text)

File #:	R-2018-204	Version: 1	Name:	Hazen & Sawyer Amendment RAS Piping & Valves	1 to ATP H&S 18-01
Туре:	Resolution		Status:	Passed	
File created:	5/29/2018		In control:	Department of Public Utilities	
On agenda:	6/20/2018		Final action:	6/20/2018	
Title:	A Resolution Of The City Commission Of The City Of Hollywood, Florida, Authorizing The Appropriate City Officials To Issue Amendment No. 1 To The Authorization To Proceed For Work Order No. H&S 18-01 With Hazen And Sawyer P.C., To Provide Professional Engineering Services For Replacement Of RAS Piping And Valves From Clarifiers No. 1 And No. 2, Located At The Southern Regional Wastewater Treatment Plant, In The Lump Sum Amount Of \$23,804.00 (Project No. 17-9523).				
Sponsors:					
Indexes:					
Code sections:					
Attachments:	1. 01 Resolution - Amendment 1 to ATP H&S 18-01 RAS Piping & Valves.pdf, 2. 02 Amendment - Amendment 1 to ATP H&S 18-01 RAS Piping & Valves.pdf, 3. 03 Draft ATP - Amendment 1 to ATP H&S 18-01 RAS Piping & Valves.pdf, 4. Term Sheet - Hazen & Sawyer Amendment NO. 1 Work Order H&S 18-01.pdf, 5. BIS 18-199.pdf				
Date	Ver. Action By		Act	ion	Result
6/20/2018	1 Regular	City Commission	Meeting add	opt	Pass
		~ · ·			· · · · · · ·

A Resolution Of The City Commission Of The City Of Hollywood, Florida, Authorizing The Appropriate City Officials To Issue Amendment No. 1 To The Authorization To Proceed For Work Order No. H&S 18-01 With Hazen And Sawyer P.C., To Provide Professional Engineering Services For Replacement Of RAS Piping And Valves From Clarifiers No. 1 And No. 2, Located At The Southern Regional Wastewater Treatment Plant, In The Lump Sum Amount Of \$23,804.00 (Project No. 17-9523).

Staff Recommends: Approval of the attached Resolution

Explanation:

The existing Return Activated Sludge (RAS) Pump Station No. 1, located at Southern Regional Wastewater Treatment Plant (SRWWTP), was constructed in 1973 and the electrical and mechanical equipment has reached the end of its useful life.

On December 6, 2017, pursuant to Resolution Number R-2017-369, the City awarded the professional technical services for the design, permitting, and bidding services for the proposed RAS Pump Station No. 1 Rehabilitation to Hazen and Sawyer, P.C. in the amount of \$74,466.00.

It has been recently determined during design by SRWWTP Operations that RAS Piping from Clarifier Nos. 1 & 2 and the associated isolation valves are beyond their useful life and require immediate replacement.

The City requested a proposal from Hazen and Sawyer, P.C. to provide Professional Engineering Services for the design, permitting, and bidding services related to the Replacement of RAS Piping and the associated isolation valves from Clarifier Nos. 1 & 2 as part of the RAS Pump Station No. 1 Rehabilitation project.

Hazen and Sawyer, P.C. and the City of Hollywood have a Professional Services Agreement for General Engineering Consulting Services for Water Treatment Plant and Wastewater Treatment Plant projects, and this agreement was approved by the City Commission pursuant to Resolution Number R-2017-283 on September 20, 2017.

The Administration recommends that the City Commission execute the attached Amendment No. 1 to Authorization to Proceed for Work Order No. H&S 18-01 with Hazen and Sawyer P.C. for the replacement of RAS piping and the associated isolation valves from Clarifier Nos. 1 & 2, together with such nonmaterial changes as may be subsequently agreed to by the City Manager and approved as to form and legal sufficiency by the City Attorney, in the lump sum amount of \$23,804.00.

Funding was included in the in the FY 2018 Capital Improvements Program that was approved via Resolution R-2017-289.

Funding is available in account number 42.4000.85597.536.003121.

Recommended for inclusion on the agenda by: Dr. Wazir A. Ishmael, City Manager Gus Zambrano, ACM, Sustainable Development Cintya Ramos, Director, Finance & Administration Steve Joseph, Director, Public Utilities Paul Bassar, Director of Procurement & Contract Compliance