

400 (C)

Discipline: FIRE

Zone:

MIC?
see email

Inspector:

Permit Number: P17-100634

IVR Number: 0002

Scheduled On: 10/03/2017

Passed/Failed: full

Inspection Type: FIRE SPRINKLER/STANDPIPE FINAL

Application Type: CONTRACTOR

Permit Type: FIRE SPRINKLER SYSTEM

Folio Number: 514213020010

Job Address: 101 N OCEAN DR

Floor: 1

Legal Description:

Relationship	Name	Phone	Phone 2
FIRE SPRINKLERS OWNER	ALL FIRE SERVICES INC	954-653-1142	954-367-3607

Date	User	Comment
08/23/2017	RLONG	HOLLYWOOD BEACH RESORT CONDO Reconnection of the Fire Alarm System to the replaced flow switches is under the the Fire Alarm System permit E17-101977 Fire Sprinkler repairs under permit numbers P17-100634 P17-100444
08/31/2017	mhofleb	Tested 4 tampers on new control valves on this date. The permit still show CA for Fire Alarm shop drawings. Fire Alarm drawings were submitted under another Fire Alarm permit that has a different scope E17-101977.
09/28/2017	mhofleb	Only need to check that all penetrations in Fire Pump room are sealed and axillary drain sign is in place.
----- Tampers for control valves for this new line were tested-OK they are on E17-101977. -----		

Ed 786-562-0165

Jordan 786-402-9349

Discipline: FIRE

Zone:

Inspector:

Permit Number: P17-100444 IVR Number: 0002

Scheduled On: 10/03/2017

Passed/Failed: Full

Inspection Type: FIRE SPRINKLER/STANDPIPE FINAL

Application Type: CONTRACTOR

Permit Type: FIRE SPRINKLER SYSTEM

Folio Number: 514213020010

Job Address: 101 N OCEAN DR

Floor: 1

Legal Description:

Relationship	Name	Phone	Phone 2
FIRE SPRINKLERS OWNER	ALL FIRE SERVICES INC	954-653-1142	954-367-3607

Date	User	Comment
08/23/2017	RLONG	HOLLYWOOD BEACH RESORT CONDO Reconnection of the Fire Alarm System to the replaced flow switches is under the the Fire Alarm System permit E17-101977 ----- Fire Sprinkler repairs under permit numbers P17-100634 P17-100444 -----